

## **Major Service - every 5 years**

It is recommended a major service be conducted on the water heater every five years.



**WARNING:** Servicing of a hot water heater must only be carried out by a qualified plumber.

**Note:** The major service and routine replacement of any components, such as the anode and relief valves are not included in the manufacturer's warranty. A charge will be made for this work.

The major service includes the following actions -

- Replace the temperature and pressure relief valve
- Replace the hot water unit anode
- Inspect and flush the cold water expansion control valve
- Test water temperature in hot water unit and adjust if necessary
- Test water temperature at tap to ensure tempering valve is working correctly
- Visually check the unit for any potential problems
- Visually check the heating element for signs of leaking
- Inspect all connections for leaks
- Check the drain line from the safe tray is not blocked
- Check and replace batteries in Mildred valve if installed